

京都府道路公社管理事務所予定使用電力量(令和4年2月～令和5年3月)

資料-2

対象建物	項目	電気使用量実績														合計
		4年2月	4年3月	4年4月	4年5月	4年6月	4年7月	4年8月	4年9月	4年10月	4年11月	4年12月	5年1月	5年2月	5年3月	
第4電気室	契約電力(kw)	80	80	80	80	80	80	80	80	80	80	80	80	80	80	
	力率(%)	97	97	97	97	97	97	97	97	97	97	97	97	97	97	
	従量(ピーク/重負荷 時間)						3,815	3,630	3,134							
	従量(昼間時間)	5,654	6,271	6,143	5,320	6,670	2,597	2,466	2,194	5,423	4,921	5,897	6,042	5,654	6,271	
	従量(夜間時間)	4,986	4,566	4,658	6,145	4,381	5,269	4,976	4,511	3,945	4,543	5,306	6,775	4,986	4,566	
計	10,640	10,837	10,801	11,465	11,051	11,681	11,072	9,839	9,368	9,464	11,203	12,817	10,640	10,837	151,715	
森TN電気室	契約電力(kw)	46	46	46	46	46	46	46	46	46	46	46	46	46	46	
	力率(%)	100	100	100	100	100	100	100	100	100	100	100	100	100	100	
	従量(ピーク/重負荷 時間)						7,142	7,119	6,754							
	従量(昼間時間)	8,895	10,616	10,190	9,623	11,876	4,479	4,112	3,361	10,433	8,488	9,395	9,129	8,895	10,616	
	従量(夜間時間)	5,424	5,521	6,386	8,406	6,285	7,375	6,834	6,107	4,811	5,423	5,395	6,585	5,424	5,521	
計	14,319	16,137	16,576	18,029	18,161	18,996	18,065	16,222	15,244	13,911	14,790	15,714	14,319	16,137	226,620	
高城TN電気室	契約電力(kw)	24	24	24	24	24	24	24	24	24	24	24	24	24	24	
	力率(%)	100	100	100	100	100	100	100	100	100	100	100	100	100	100	
	従量(ピーク/重負荷 時間)						3,192	3,152	3,011							
	従量(昼間時間)	4,014	4,749	4,550	3,937	4,965	1,842	1,734	1,475	4,597	3,796	4,229	4,025	4,014	4,749	
	従量(夜間時間)	2,683	2,824	3,015	3,717	2,865	3,608	3,477	3,103	2,405	2,745	2,700	3,105	2,683	2,824	
計	6,697	7,573	7,565	7,654	7,830	8,642	8,363	7,589	7,002	6,541	6,929	7,130	6,697	7,573	103,785	
第5電気室	契約電力(kw)	34	34	34	34	34	34	34	34	34	34	34	34	34	34	
	力率(%)	98	98	98	98	98	98	98	98	98	98	98	98	98	98	
	従量(ピーク/重負荷 時間)						4,287	3,909	3,393							
	従量(昼間時間)	5,001	5,995	6,494	5,534	7,011	2,359	2,146	1,946	5,521	4,226	4,579	4,913	5,001	5,995	
	従量(夜間時間)	3,583	3,433	3,827	5,157	3,713	4,558	4,265	3,910	3,175	3,497	3,628	4,398	3,583	3,433	
計	8,584	9,428	10,321	10,691	10,724	11,204	10,320	9,249	8,696	7,723	8,207	9,311	8,584	9,428	132,470	
新瑞穂TN電気室	契約電力(kw)	77	77	77	77	77	77	77	77	77	77	77	77	77	77	
	力率(%)	100	100	100	100	100	100	100	100	100	100	100	100	100	100	
	従量(ピーク/重負荷 時間)						7,118	6,896	6,595							
	従量(昼間時間)	11,524	13,721	11,664	9,924	12,378	4,916	4,608	4,108	12,904	11,297	13,463	12,946	11,524	13,721	
	従量(夜間時間)	9,510	9,688	9,412	10,563	7,877	9,481	9,147	8,393	7,877	9,712	10,891	12,308	9,510	9,688	
計	21,034	23,409	21,076	20,487	20,255	21,515	20,651	19,096	20,781	21,009	24,354	25,254	21,034	23,409	303,364	
第3電気室	契約電力(kw)	39	39	39	39	39	39	39	39	39	39	39	39	39	39	
	力率(%)	95	95	95	95	95	95	95	95	95	95	95	95	95	95	
	従量(ピーク/重負荷 時間)						2,953	2,724	2,465							
	従量(昼間時間)	4,294	4,294	4,447	3,765	4,825	1,768	1,648	1,452	3,965	3,117	4,106	4,312	4,294	4,294	
	従量(夜間時間)	3,853	3,282	2,887	3,738	2,845	3,482	3,279	3,065	2,597	2,891	4,305	5,278	3,853	3,282	
計	8,147	7,576	7,334	7,503	7,670	8,203	7,651	6,982	6,562	6,008	8,411	9,590	8,147	7,576	107,360	
第7電気室	契約電力(kw)	14	14	14	14	14	14	14	14	14	14	14	14	14	14	
	力率(%)	100	100	100	100	100	100	100	100	100	100	100	100	100	100	
	従量(ピーク/重負荷 時間)						1,383	1,337	1,204							
	従量(昼間時間)	1,842	1,952	1,948	1,866	2,403	1,053	1,010	922	2,037	1,801	1,972	1,840	1,842	1,952	
	従量(夜間時間)	1,912	1,740	1,760	2,135	1,798	2,188	2,128	1,989	1,634	1,784	1,966	2,495	1,912	1,740	
計	3,754	3,692	3,708	4,001	4,201	4,624	4,475	4,115	3,671	3,585	3,938	4,335	3,754	3,692	55,545	

広野TN電気室	契約電力(kw)	46	46	46	46	46	46	46	46	46	46	46	46	46	46	46
	力率(%)	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
	従量(ピーク/重負荷 時間)						4,410	4,143	3,906							12,459
	従量(昼間時間)	5,438	6,105	6,219	5,263	6,913	2,329	2,146	1,836	5,734	5,105	5,696	5,669	5,438	6,105	69,996
	従量(夜間時間)	3,524	3,185	3,577	4,766	3,402	4,245	4,013	3,686	2,941	3,438	3,680	4,769	3,524	3,185	51,935
計	8,962	9,290	9,796	10,029	10,315	10,984	10,302	9,428	8,675	8,543	9,376	10,438	8,962	9,290	134,390	
第1電気室	契約電力(kw)	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23
	力率(%)	92	92	92	92	92	92	92	92	92	92	92	92	92	92	92
	従量(ピーク/重負荷 時間)						784	791	699							2,274
	従量(昼間時間)	2,046	1,813	1,533	1,474	1,691	1,014	1,067	1,048	1,924	1,627	2,150	2,242	2,046	1,813	23,488
	従量(夜間時間)	3,222	2,351	2,039	2,606	1,930	2,341	2,392	2,282	2,307	2,182	3,591	4,430	3,222	2,351	37,246
計	5,268	4,164	3,572	4,080	3,621	4,139	4,250	4,029	4,231	3,809	5,741	6,672	5,268	4,164	63,008	
栗野TN電気室	契約電力(kw)	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35
	力率(%)	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
	従量(ピーク/重負荷 時間)						4,989	5,576	5,309							15,874
	従量(昼間時間)	6,844	8,184	7,919	6,955	8,047	2,888	2,931	2,474	8,112	6,549	7,197	6,866	6,844	8,184	89,994
	従量(夜間時間)	4,081	4,129	4,902	6,031	4,109	4,847	5,189	4,756	3,807	4,209	3,988	4,835	4,081	4,129	63,093
計	10,925	12,313	12,821	12,986	12,156	12,724	13,696	12,539	11,919	10,758	11,185	11,701	10,925	12,313	168,961	
京丹波わちIC電気室	契約電力(kw)	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56
	力率(%)	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99
	従量(ピーク/重負荷 時間)						3,777	3,828	3,061							10,666
	従量(昼間時間)	9,575	9,531	7,329	5,671	6,640	3,749	3,862	3,392	7,692	7,897	10,705	10,909	9,575	9,531	106,058
	従量(夜間時間)	13,665	12,527	10,481	9,347	6,934	8,530	8,646	7,708	8,961	11,394	14,826	17,933	13,665	12,527	157,144
計	23,240	22,058	17,810	15,018	13,574	16,056	16,336	14,161	16,653	19,291	25,531	28,842	23,240	22,058	273,868	
京丹波みずほIC電気室	契約電力(kw)	45	45	45	45	45	45	45	45	45	45	45	45	45	45	45
	力率(%)	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
	従量(ピーク/重負荷 時間)						2,428	2,460	2,200							7,088
	従量(昼間時間)	7,549	7,273	5,388	4,448	5,090	2,650	2,695	2,589	5,714	5,487	8,115	8,356	7,549	7,273	80,176
	従量(夜間時間)	10,505	9,501	7,756	7,477	5,737	6,247	6,252	6,098	6,643	7,963	11,303	13,616	10,505	9,501	119,104
計	18,054	16,774	13,144	11,925	10,827	11,325	11,407	10,887	12,357	13,450	19,418	21,972	18,054	16,774	206,368	
第2電気室	契約電力(kw)	38	38	38	38	38	38	38	38	38	38	38	38	38	38	38
	力率(%)	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99
	従量(ピーク/重負荷 時間)						3,938	3,669	3,405							11,012
	従量(昼間時間)	5,217	5,793	6,133	4,783	6,302	2,067	1,911	1,714	5,275	4,190	5,051	5,181	5,217	5,793	64,627
	従量(夜間時間)	3,847	3,394	3,437	4,448	3,232	4,078	3,802	3,557	2,807	3,312	4,133	5,047	3,847	3,394	52,335
計	9,064	9,187	9,570	9,231	9,534	10,083	9,382	8,676	8,082	7,502	9,184	10,228	9,064	9,187	127,974	
京丹波PA電気室	契約電力(kw)	111	111	111	111	111	111	111	111	111	111	111	111	111	111	111
	力率(%)	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
	従量(ピーク/重負荷 時間)						8,831	8,771	8,555							26,157
	従量(昼間時間)	13,152	16,549	15,029	12,841	15,592	6,350	6,408	5,902	16,306	14,527	15,330	13,325	13,152	16,549	181,012
	従量(夜間時間)	11,253	11,468	11,536	13,911	9,864	12,023	11,763	11,365	10,601	12,790	12,178	13,561	11,253	11,468	165,034
計	24,405	28,017	26,565	26,752	25,456	27,204	26,942	25,822	26,907	27,317	27,508	26,886	24,405	28,017	372,203	
第10電気室	契約電力(kw)	69	69	69	69	69	69	69	69	69	69	69	69	69	69	69
	力率(%)	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99
	従量(ピーク/重負荷 時間)						4,930	4,967	4,350							14,247
	従量(昼間時間)	12,785	12,546	9,980	8,225	9,733	5,435	5,582	5,169	11,028	10,538	14,012	14,461	12,785	12,546	144,825
	従量(夜間時間)	17,122	15,753	14,010	13,809	10,734	12,715	12,913	12,041	12,787	15,050	18,819	22,477	17,122	15,753	211,105
計	29,907	28,299	23,990	22,034	20,467	23,080	23,462	21,560	23,815	25,588	32,831	36,938	29,907	28,299	370,177	

第9電気室	契約電力(kw)	51	51	51	51	51	51	51	51	51	51	51	51	51	51	51	
	力率(%)	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	
	従量(ピーク/重負荷 時間)							3,706	3,624	3,383							10,713
	従量(昼間時間)	5,955	6,815	6,697	5,705	6,914	3,101	3,048	2,849	6,371	5,517	6,466	6,657	5,955	6,815	78,865	
	従量(夜間時間)	5,477	5,371	5,711	7,162	5,749	6,612	6,569	6,207	5,045	5,491	5,762	7,230	5,477	5,371	83,234	
計	11,432	12,186	12,408	12,867	12,663	13,419	13,241	12,439	11,416	11,008	12,228	13,887	11,432	12,186	172,812		
第6電気室	契約電力(kw)	98	98	98	98	98	98	98	98	98	98	98	98	98	98	98	
	力率(%)	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	
	従量(ピーク/重負荷 時間)							11,674	11,956	10,498							34,128
	従量(昼間時間)	22,533	23,462	20,043	17,681	22,364	11,556	12,011	11,012	22,379	20,582	25,368	24,521	22,533	23,462	279,507	
	従量(夜間時間)	25,058	24,765	23,854	26,158	22,169	25,835	26,635	24,778	21,939	25,044	27,147	30,672	25,058	24,765	353,877	
計	47,591	48,227	43,897	43,839	44,533	49,065	50,602	46,288	44,318	45,626	52,515	55,193	47,591	48,227	667,512		
横谷TN電気室	契約電力(kw)	47	47	47	47	47	47	47	47	47	47	47	47	47	47	47	
	力率(%)	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	
	従量(ピーク/重負荷 時間)							4,118	3,859	3,592							11,569
	従量(昼間時間)	5,651	6,392	6,160	5,680	7,387	3,207	3,093	2,756	6,375	5,417	6,003	5,841	5,651	6,392	76,005	
	従量(夜間時間)	5,650	5,559	5,726	6,852	5,481	6,798	6,645	5,938	4,947	5,729	6,073	6,860	5,650	5,559	83,467	
計	11,301	11,951	11,886	12,532	12,868	14,123	13,597	12,286	11,322	11,146	12,076	12,701	11,301	11,951	171,041		
第8電気室	契約電力(kw)	37	37	37	37	37	37	37	37	37	37	37	37	37	37	37	
	力率(%)	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	
	従量(ピーク/重負荷 時間)							3,059	2,901	2,709							8,669
	従量(昼間時間)	5,402	5,378	5,389	4,228	5,276	2,127	1,999	1,831	4,611	4,161	5,590	5,975	5,402	5,378	62,747	
	従量(夜間時間)	4,838	3,928	3,833	4,629	3,655	4,339	4,191	3,911	3,162	3,612	5,117	6,933	4,838	3,928	60,914	
計	10,240	9,306	9,222	8,857	8,931	9,525	9,091	8,451	7,773	7,773	10,707	12,908	10,240	9,306	132,330		
綾部安国寺IC電気室	契約電力(kw)	40	40	40	40	40	40	40	40	40	40	40	40	40	40	40	
	力率(%)	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	
	従量(ピーク/重負荷 時間)							2,823	2,901	2,356							8,080
	従量(昼間時間)	7,346	7,495	5,979	4,554	5,233	3,068	3,235	2,878	6,588	6,534	8,552	8,200	7,346	7,495	84,503	
	従量(夜間時間)	10,674	10,194	9,163	8,228	5,993	7,192	7,444	6,774	8,429	10,024	11,942	13,227	10,674	10,194	130,152	
計	18,020	17,689	15,142	12,782	11,226	13,083	13,580	12,008	15,017	16,558	20,494	21,427	18,020	17,689	222,735		
橋上TN電気室	契約電力(kw)	44	44	44	44	44	44	44	44	44	44	44	44	44	44	44	
	力率(%)	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	
	従量(ピーク/重負荷 時間)							2,964	2,847	2,687							8,498
	従量(昼間時間)	4,097	4,720	4,583	4,069	5,184	2,272	2,199	1,954	4,785	3,968	4,392	4,171	4,097	4,720	55,211	
	従量(夜間時間)	3,792	3,762	3,979	4,755	3,736	4,663	4,614	4,093	3,576	3,920	4,033	4,514	3,792	3,762	56,991	
計	7,889	8,482	8,562	8,824	8,920	9,899	9,660	8,734	8,361	7,888	8,425	8,685	7,889	8,482	120,700		
合計	契約電力(kw)																
	力率(%)																
	従量(ピーク/重負荷 時間)	0	0	0	0	0	92,321	91,060	83,266	0	0	0	0	0	0	266,647	
	従量(昼間時間)	154,814	169,654	153,817	131,546	162,494	70,827	69,911	62,862	157,774	139,745	168,268	165,581	154,814	169,654	1,931,761	
	従量(夜間時間)	154,659	146,941	141,949	160,040	122,489	146,426	145,174	134,272	124,396	144,753	166,783	197,048	154,659	146,941	2,086,530	
計	309,473	316,595	295,766	291,586	284,983	309,574	306,145	280,400	282,170	284,498	335,051	362,629	309,473	316,595	4,284,938		

- (注1) 重負荷時間 7月1日～9月30日の10時～17時(日曜日及び祝日の該当時間を除く。)  
 昼間時間 8時～22時(重負荷時間、日曜日及び祝日の該当時間を除く。)  
 夜間時間 「重負荷時間」及び「昼間時間」以外の時間
- (注2) 契約電力は、電気使用量実績(令和3年9月)の値を用いています。
- (注3) 力率は、電気使用量実績(令和3年9月)の値を用いています。
- (注4) 予定使用電力量は、使用電力量を確約するものではなく、見込まれる使用電力量であり、実際の使用電力量は増減する場合があります。